



Product certificate K13074/05

Issued 2022-02-01

Replaces K13074/04

Page 1 of 2

Wall plate brackets for sanitary taps

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Valf Sanayii A.S.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K623 "Plumbing fittings for capillary soldering and/or thread connections to copper tubes", dated 2019-10-01,

which covers the requirements of

EN 1254-1, 1998: "Copper and copper alloys – Plumbing fittings – Part 1: Fittings with ends for capillary soldering or capillary brazing to copper tubes."

and

EN 1254-4, 1998: "Copper and copper alloys – Plumbing fittings – Part 4: Fittings combining other end connections with capillary or compression ends."

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

287180711

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Valf Sanayii A.S.
Organize San. Bölgesi 1
45030 MANISA
Turkey
Tel. +90 (0)236 233 2560
valf@valf.com.tr
www.valf.com.tr



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Wall plate brackets for sanitary taps

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate

Wallplate brackets, low model, with connection ends

(internal thread * capillary), ISO 228

Type	Article number	Design
11022	102990730	12 mm * G¾A
11022	102890740	15 mm * G½A

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA  or  .

Place of the mark: on the fitting.

*) for small fittings, marking with only  is permitted.

Compulsory specifications:

- name or logo of the manufacturer;
- data or code indicating the date of production;
- type indication.

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

The plumbing fittings are used to make capillary soldering and/or thread connections, in drinking water installations and in heating installations.

The plumbing fittings are intended for use in combination with copper pipes according to the Kiwa guideline BRL-K760.

For the application in drinking water installations, a maximum working pressure of 1000 kPa and a maximum water temperature of 90 °C is applicable.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Valf Sanayii A.S.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.